Scanned with OKEN Scanner

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.

No. 201 Date : 24.04.26.

It is certified that an inspection team headed by Rahul Ranjan Assistant Engineer (Name of Officers with designation) from P.H. Sub. Division Biharsharif (Name of Department/Office) inspected the R.P.S. School Makanpur, Ekangarsarai Road, Nalanda (Name & Address of the School) on 24.04.2026 and found that the R.P.S. School Makanpur, Ekangarsarai Road, Nalanda (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Signature with Seal : 24-4-2026

Name : Rahul Ranjan

Designation : Assistant Engineer

अवर प्रमण्डल पदाधिकार
लोक स्वा० अवर प्रमण्डल
बिहार शरीफ (नालन्दा)

To

R.P.S. School
Makanpur, Ekangarsarai
Road, Nalanda - 803118

(Name & Address of the Institution)

L-30/26-Date-24/04/2026

Government of Bihar

Publice Health Engineering Department

Water Quality Report

Division Name: Public Health Engineering Division, Biharsharif & Hilsa

District Name: Nalanda

Sample Collected by : - Ref no-RPS/MKN/NAL/451 Bishnu Kumar.

Date of Sampling :- 22/04/2026

Sl. No.	Block	Panchayat	Village	Habibtation	Location of Source	Test result													Source of Water
						pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO_3	SO_4	F	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20
1	Noorsarai	Tiyari	Makanpur	Makanpur	R.P.S School, Makanpur, Ekangar Sarai, Road	7.87	0.19	396	261	150	40	12	40	160	0.1	<1.0	10.2	0.659	Tap water
					Desirable Limit	6.5-8.5	1	-	500		75	30	250	200	1	45	200	1	-
					Permissible Limit* in absence of alternate source	NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-

Chandra. 24/04/2026

Chemist
Public Health Division, Biharsharif
(Nalanda)

Chemist
Public Health Division
Bihar Sharif (Nalanda)

Scanned with OKEN Scanner